



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 13-9, **Version:** 2

Appeal of Julie Peterson to a Fire Certificate of Occupancy Correction Notice at 1447 WHITE BEAR AVENUE NORTH.

We have an older house and would like our upper bedroom window dimensions to be accepted so that foster care children may occupy those rooms. Currently, they are 19" high by 24" wide.

July 26, 2013

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Julie Peterson to a Fire Certificate of Occupancy Correction Notice at 1447 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the upper east and southside bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.