



Legislation Text

File #: RLH FOW 12-107, **Version:** 2

Appeal of Bruce Hoffmann to a Fire Certificate of Occupancy Inspection Correction Notice at 1945 HAWTHORNE AVENUE EAST.

Openable height is 22" and width is 27".

March 6, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height for the attic window. (Orders were not necessary for windows of these dimensions.)

WHEREAS, in the matter of the Appeal of Bruce Hoffmann to a Fire Certificate of Occupancy Inspection Correction Notice at 1945 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the attic bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.