



Legislation Text

File #: RLH WP 12-5, **Version:** 2

Appeal of Derek Tanberg, on behalf of The Window Store Home Improvements, Inc., to an Egress Window Non-Compliance Determination at 1046 STINSON STREET.

These windows just miss on qualifying for egress. Julie Rohlik doesn't want 2 windows in the house to miss match the rest of her new windows.

January 6, 2012

J. Hoffman

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Derek Tanberg, on behalf of The Window Store Home Improvements, Inc., to an Egress Window Non-Compliance Determination at 1046 STINSON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.34 inches wide.; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.