



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-157, **Version:** 2

---

Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 1076 CYPRESS STREET.

#4 Interior - MSFC 1026.1 Request variance on openable height.

August 18, 2011

Yes, 6 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 1076 CYPRESS STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress window in the upstairs bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.