



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-98, **Version:** 2

Appeal of Ted Ryden to an Egress Window Non-Compliance Determination at 1011 MATILDA STREET.

None listed

Yes, 1/2 inch variance in egress opening width.

DSI staff: There is no staff signature on the form. Also, 1/2 inch seems extremely picky and punitive for the issuance of this permit.

WHEREAS, in the matter of the Appeal of Ted Ryden to an Egress Window Non-Compliance Determination at 1011 MATILDA STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a .5-inch variance on the openable width of one 2-section sliders replacement egress bedroom window measuring 36-9/16 inches high by 19.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.