



## Legislation Text

---

**File #:** RLH FCO 12-13, **Version:** 2

---

Appeal of Tamer Azzazi to a Fire Certificate of Occupancy Correction Notice at 1849 REANEY AVENUE.

Ceiling height.

Windows - have width met if rotated 90 deg.

#6 bedroom size?

At time of inspection, 4 children were watching tv in bedroom

December 15, 2011

James Thomas

Hearing on ceiling height issue and bedroom size.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tamer Azzazi to a Fire Certificate of Occupancy Correction Notice at 1849 REANEY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the basement ceiling height and basement west and east side occupancy loads - granting an extension of 90-days to come into compliance and grant a 4-inch variance on the openable height of the egress windows in the west side and northwest side bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.