



## Legislation Text

---

**File #:** RLH WP 11-26, **Version:** 2

---

Appeal of Renewal by Andersen, on behalf of Annette and Kirby Hanson, to an Egress Window Non-Compliance Determination at 2221 EDGCUMBE ROAD.

We are appealing 3 replacement windows that will not comply w/egress policy. Opening width will be 17" and openable height will be exceeded by 10." These windows are less than 3' from sill to grade. Please approve...

May 26, 2011

Yes, 3 inches in the openable width of the egress windows. No hearing necessary.

WHEREAS, in the matter of the appeal of Renewal by Andersen, on behalf of Annette and Kirby Hanson, to an Egress Window Non-Compliance Determination at 2221 EDGCUMBE ROAD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of three casement replacement egress bedroom windows measuring 34 1/4 inches high by 17 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.