



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-63, **Version:** 2

---

Appeal of Ker Moua to an Egress Window Non-Compliance Determination at 922 WILSON AVENUE.

The window did not pass bulding inspection for sleeping room. [sic]

August 24, 2011

Yes, 4 inches in the egress opening width. No hearing necessary

WHEREAS, in the matter of Appeal of Ker Moua to an Egress Window Non-Compliance Determination at 922 WILSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable width of one casement replacement egress bedroom window measuring 43 inches high by 16.25 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.