



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-169, **Version:** 2

Appeal of Floyd Johnson to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 503 FOREST STREET.

Only egress windows (see letter for details)

September 15, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Floyd Johnson to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 503 FOREST STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the lower unit, northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.