



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-36, **Version:** 2

---

Appeal of Justin Fox to a Fire Certificate of Occupancy Inspection Correction Notice at 1381 REANEY AVENUE.

I am appealing numbers 1 and 6...

December 30, 2011

James Thomas

No hearing necessary.

Fire staff, can you confirm item #1 in orders? It may be redundant with #6.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Justin Fox to a Fire Certificate of Occupancy Inspection Correction Notice at 1381 REANEY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.