



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-135, **Version:** 2

Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 757 IGLEHART AVENUE.

egress windows

March 13, 2012

Rick Gavin

No hearing necessary.

Yes - 4-inch variance width in egress opening.

WHEREAS, in the matter of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 757 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable width of the egress windows in all bedrooms measuring 45 inches high by 16 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.