



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 10-303, **Version:** 1

Appeal of Josh Cook and Jennifer Klein to an Egress Window Non-Compliance Determination at 558 Ottawa Avenue.

558 Ottawa Avenue

Variance on egress bedroom windows. They do not reach the 24" height, but have a 22" height and 25.5" width.

October 6, 2010

No hearing necessary, as only windows under appeal.
Grant variance of 2" in openable height.