



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-208, **Version:** 2

Appeal of Pat Kirkwold to a Fire Certificate of Occupancy Correction Notice at 415 HOYT AVENUE EAST.

Refer to attachment in response to Items 6, 7.

September 20, 2011

Yes, basement northeast bedroom sill height - install 2 standard size steps for the length of the window.
Hearing on the balance of the appeal.

WHEREAS, in the matter of the Appeal of Pat Kirkwold to a Fire Certificate of Occupancy Correction Notice at 415 HOYT AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a variance on the sill height in the basement northeast bedroom on the condition that two steps are installed full width below the egress window; deny a variance on the basement northeast and south bedrooms and grant an extension for 90 days to come into compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.