



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-96, **Version:** 2

---

Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 1570 CHAMBER STREET.

#1 Bedroom - Request variance on openable width.

February 24, 2012

Mike Cassidy

Hearing necessary, unless owner can demonstrate window opens to a width of 16 inches.

WHEREAS, in the matter of the Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 1570 CHAMBER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance egress opening height for the northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.