



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-29, **Version:** 2

Appeal of Window World, on behalf of Norm Lee, to an Egress Window Non-Compliance Determination at 1311 CLARENCE STREET.

Asking for variance on windows.

April 22, 2011

Yes, 10 inches in sill height requirement, if 2 steps of standard dimensions are installed for the full length of the glazed area.

WHEREAS, in the matter of the appeal of Window World, on behalf of Norm Lee, to an Egress Window Non-Compliance Determination at 1311 CLARENCE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal provided two steps of standard dimensions are installed to address the sill height issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.