



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-276, **Version:** 2

---

Appeal of Cheryl Barsten to a Correction Notice-Complaint Inspection at 915 HAWTHORNE AVENUE EAST.

Re: Property in the attached deficiency list - The expense of replacing windows would be a hardship for me. I will be operating my child care business in the basement. These windows are on the second level.

June 26, 2012

James Perucca

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Cheryl Barsten to a Correction Notice-Complaint Inspection at 915 HAWTHORNE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the two second story bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.