



Legislation Text

File #: RLH FCO 16-197, **Version:** 2

Appeal of Jessica Hindmarch to a Fire Inspection Correction Notice at 69 SEVENTH STREET EAST.

Any photos or diagrams which may help explain the situation are appreciated. MM

WHEREAS, in the matter of the Appeal of Jessica Hindmarch to a Fire Inspection Correction Notice at 69 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal if one of the following conditions is met:

1. the motion sensor (access control) stays in place and a labeled push panic button is installed;
2. the motion sensor (access control) stays in place and it can be confirmed the handicap button can be used for emergency access and is so labeled; or
3. the motion sensor (access control) is disconnected; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.