



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 11-376, **Version:** 1

Appeal of Steven Johnson to a Fire Inspection Correction Notice at 983 JAMES AVENUE.

Window is 5.2 sq ft glass needs to be 5.0 sq ft glass. Older style window odd dimensions!!!

February 22, 2011

No hearing necessary. Recommend variance on egress window dimensions.