



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 11-376, **Version:** 1

---

Appeal of Steven Johnson to a Fire Inspection Correction Notice at 983 JAMES AVENUE.

Window is 5.2 sq ft glass needs to be 5.0 sq ft glass. Older style window odd dimensions!!!

February 22, 2011

No hearing necessary. Recommend variance on egress window dimensions.