



Legislation Text

File #: RLH WP 11-43, **Version:** 2

Appeal of Champion Window Company to an Egress Window Non-Compliance Determination at 1402 WOODBRIDGE STREET.

Egress windows

June 23, 2011

Grant the appeal.

WHEREAS, in the matter of Appeal of Champion Window Company to an Egress Window Non-Compliance Determination at 1402 WOODBRIDGE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of three double hung replacement egress windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.