



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-39, **Version:** 2

---

Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1688 HYACINTH AVENUE EAST.

Windows

April 24, 2012

No hearing necessary.

Yes, 4.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1688 HYACINTH AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4.5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19.9 inches high by 25.3 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.