



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-62, **Version:** 2

---

Appeal of Greg Fry to an Egress Window Non-Compliance Determination at 2209/2211 GLENRIDGE AVENUE.

Windows

June 1, 2012

David Nelson

No hearing necessary.

Unclear as to why noncompliance determination was issued.

Yes, 2 inches for listed windows.

WHEREAS, in the matter of the Appeal of Greg Fry to an Egress Window Non-Compliance Determination at 2209/2211 GLENRIDGE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of twelve double hung replacement egress bedroom windows measuring 22 inches high by 33 inches wide for Units 2209 and 2211; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.