



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 12-652, **Version:** 2

Appeal of Matt Connelly to a Fire Inspection Correction Notice at 1966 BENSON AVENUE.

Roll storage from 12 feet to 16 feet.

December 6, 2012

Mitchell Imbertson

AMENDED 2/20/13

WHEREAS, in the matter of the Appeal of Matt Connelly to a Fire Inspection Correction Notice at 1966 BENSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a storage height variance of 2 feet, allowing that the paper rolls may be stored to a height of 14 feet, with a deadline for compliance of March 1, 2013; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby ~~accepts and adopts the Legislative Hearing Officer's recommendation in this matter~~ grants the appeal.