



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-137, **Version:** 2

Appeal of Sy Vang Mouacheupao to a Fire Certificate of Occupancy Inspection Correction Notice at 1255 EDGERTON STREET.

Windows - See attachment

April 3, 2012

Mike Cassidy

No hearing necessary.

Yes, 2.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Sy Vang Mouacheupao to a Fire Certificate of Occupancy Inspection Correction Notice at 1255 EDGERTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable height of the egress windows in the first floor northeast, southwest and south bedrooms and second floor northeast bedroom, and grant a 7-inch variance on the openable height of the egress window in the second floor west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.