



Legislation Text

File #: RLH WP 11-38, **Version:** 2

Appeal of Trikin Holdings to an Egress Window Non-Compliance Determination at 697 FIFTH STREET EAST.

(Nothing noted)

June 21, 2011

Yes, 2 inches in the egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Trikin Holdings to an Egress Window Non-Compliance Determination at 697 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of one replacement egress bedroom window in the upper unit measuring 30 inches high by 18 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.