



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-34, **Version:** 2

Appeal of Emmanuel D'Huyvetter to an Egress Window Non-Compliance Determination at 1375 MARGARET STREET.

Only egress windows

June 24, 2011

Yes, 3 inches in the egress opening width. No hearing necessary.

WHEREAS, in the matter of the appeal of Emmanuel D'Huyvetter to an Egress Window Non-Compliance Determination at 1375 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; AND

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of two slider replacement egress bedroom windows measuring 39 inches high by 17 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.