



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-117, **Version:** 2

Appeal of Daniel Schmidt, Department of Public Health, on behalf of Lue Williams, to an Egress Window Non-Compliance Determination 844 FULLER AVENUE.

[Enter the Reason for the Appeal]

November 16, 2011

Public Health.

No hearing necessary.

Yes, 2 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Department of Public Health, on behalf of Lue Williams, to an Egress Window Non-Compliance Determination 844 FULLER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 22.6 inches high by 22 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.