



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-274, **Version:** 2

Appeal of Jim Sundberg to a Fire Inspection Correction Notice at 746 SIMON AVENUE.

#7 on attached list - The window is 2" short on required height but 5" over on required width. This should be ample size for escape if needed.

June 6, 2012

Sebastian Migdal

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Jim Sundberg to a Fire Inspection Correction Notice at 746 SIMON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in Unit 1 bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.