



Legislation Text

File #: RLH FOW 11-63, **Version:** 2

Appeal of Scott John Lund to a Fire Certificate of Occupancy Correction Notice at 1534 LARPEN TEUR AVENUE EAST.

Bedroom windows open 23" high to 23 1/4" (house is 8 years old).

May 17, 2011

Yes, 1-inch in the opening height.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Scott John Lund to a Fire Certificate of Occupancy Correction Notice at 1534 LARPEN TEUR AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress bedroom windows for Item 8 of the May 17, 2011 Correction Notice; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.