



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-35, **Version:** 2

Appeal of Joe Urbanski, on behalf of J&D Builders Inc, to an Egress Window Non-Compliance Determination at 1954 BEECHWOOD AVENUE.

Egress window non-compliance

Michael Palm

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Joe Urbanski, on behalf of J&D Builders Inc, to an Egress Window Non-Compliance Determination at 1954 BEECHWOOD AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;
and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the third floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.