



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-274, **Version:** 2

---

Appeal of Bie Drake to a Correction Notice-Daycare Inspection at 1309 MAYNARD DRIVE WEST.

The minimum size of glazed area with a minimum of 22 inches instead of 24 inches of openable height.

December 5, 2011

James Perruca

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of Appeal of Bie Drake to a Correction Notice-Daycare Inspection at 1309 MAYNARD DRIVE WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in bedroom 1 east window and bedroom 2 south window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.