



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** ALH 11-416, **Version:** 1

---

Appeal of Kibrom Haile to a Fire Inspection Correction Notice at 235 ANN STREET.

egress windows, double hung opening 20" h by 26" w. Glazed area 41" h by 23.5" w.

January 24, 2011

No hearing necessary. Recommend variance on egress window opening dimensions.