



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH OA 20-6, **Version:** 2

---

Appeal of Erandi Lindsey to an e-mail from the Department of Safety and Inspections (DSI) dated 5/13/2020 regarding a Septic System at 2108 SKYWAY DRIVE.

WHEREAS, in the matter of the Appeal of Erandi Lindsey to an e-mail from the Department of Safety and Inspections (DSI) dated 5/13/2020 regarding a septic system at 2108 Skyway Drive, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 25 ft variance of the 75 ft setback requirement for separation of the septic tank and well; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.