



Legislation Text

File #: RLH FOW 12-188, **Version:** 2

Appeal of Dana Tregilgos Johnson to a Fire Certificate of Occupancy Inspection Correction Notice at 2117 JEFFERSON AVENUE.

Only Egress Windows (see attachment)

May 1, 2012

Jay Bohan

Hearing necessary for window with egress opening of 15"H x 32"W.

Yes, 7 inches for window with egress opening of 34"W x 17"H.

WHEREAS, in the matter of the Appeal of Dana Tregilgos Johnson to a Fire Certificate of Occupancy Inspection Correction Notice at 2117 JEFFERSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in the second floor north and south side bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.