



Legislation Text

File #: RLH WP 12-36, **Version:** 2

Appeal of Justin Nelson to an Egress Window Non-Compliance Determination at 2101 BURNS AVENUE.

(2) Egress windows on main level

April 24, 2012

R. Rehn

No hearing necessary.

Yes, 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of Justin Nelson to an Egress Window Non-Compliance Determination at 2101 BURNS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 17 inches high by 37 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.