



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-28, **Version:** 2

Appeal of Window World, on behalf of Craig Wieber, to an Egress Window Non-Compliance Determination at 2088 CALIFORNIA AVENUE EAST.

Asking for variance on windows.

January 18, 2011

Yes, 8 inches in opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Window World, on behalf of Craig Wieber, to an Egress Window Non-Compliance Determination at 2088 CALIFORNIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 16 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.