



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 11-475, **Version:** 1

Appeal of Sarah Kinney to a Rescheduled Fire Inspection Correction Notice at 433 HOLLY AVENUE.

Window is 22" high, 24" required

March 14, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of

[title]

the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends [recommendation]

now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.