



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-256, **Version:** 2

Appeal of Larry Johanns to a Fire Certificate of Occupancy Inspection Correction Notice at 807 WHITE BEAR AVENUE NORTH.

Bedroom south side, the opening height is 23 inches.

June 5, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Larry Johanns to a Fire Certificate of Occupancy Inspection Correction Notice at 807 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the south side bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.