



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-102, **Version:** 2

---

Appeal of Ignatius Kadoma to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1739 FIFTH STREET EAST.

Attic: Required 24" open height X 20" open width; I have 19" open height X 27" open width

June 30, 2011

Yes, 5 inches in openable height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Ignatius Kadoma to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1739 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the attic; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.