



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-89, **Version:** 2

Appeal of Jason Martinetto, Re/Max Specialists, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2008 RAMLOW PLACE.

Appealing the need to replace adequate sized windows due to sill height.

June 17, 2011

Yes, 5 inches on the minimum sill height on the condition that a standard sized step be installed for the full width of the egress window.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Jason Martinetto, Re/Max Specialists, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 2008 RAMLOW PLACE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the sill height issue on the condition that a standard sized full-width step is installed below the egress windows in all three bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.