



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-18, **Version:** 2

---

Appeal of the Saint Paul - Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 646 VAN BUREN AVENUE.

Egress windows

April 28, 2011

Yes, 5 inches in opening height.

WHEREAS, in the matter of the appeal of Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 646 VAN BUREN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; And

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5 inch variance in the opening height of the egress window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.