



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-65, **Version:** 2

Appeal of The Home Depot At-Home Services, on behalf of Robin Fate, to an Egress Window Non-Compliance Determination at 1191 FAIRMOUNT AVENUE.

(Nothing noted)

August 24, 2011

Yes, 5 inches in opening height.

WHEREAS, in the matter of the Appeal of The Home Depot At-Home Services, on behalf of Robin Fate, to an Egress Window Non-Compliance Determination at 1191 FAIRMOUNT AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high x 24.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.