



## Legislation Text

---

**File #:** RLH FOW 11-49, **Version:** 2

---

Appeal of William B. Becker to a Fire Inspection Correction Notice at 2072 MOHAWK AVENUE.

Need variance for bedroom window. Has been inspected numerous times & has passed. Window is within inches one direction & over in other direction.

March 24, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of William B. Becker to a Fire Inspection Correction Notice at 2072 MOHAWK AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the upper unit southwest bedroom; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.