



Legislation Text

File #: RLH FCO 12-513, **Version:** 2

Appeal of Alissa Kellogg to a Correction Notice-Complaint Inspection at 316 ROBERT STREET NORTH, SKYWAY 35.

Building under construction.

July 25, 2012

Kris Skow-Fiske

[Enter Legislative Hearing Staff Comments and Questions for Department Staff]

WHEREAS, in the matter of the Appeal of Alissa Kellogg to a Correction Notice-Complaint Inspection at 316 ROBERT STREET NORTH, SKYWAY 35, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the condition that the skyway pedestrian system is maintained at temperature level of 55-85 degrees, plus or minus 15 degrees Fahrenheit; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.