



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 13-59, **Version:** 2

Appeal of Charles Cory, on behalf of Big Steer Meats, to a Re-Inspection Fire Certificate of Occupancy with Deficiencies at 1766 MINNEHAHA AVENUE EAST.

#3 on Fire Inspection Report (believe he means #1-me)

February 28, 2013

Wayne Spiering

WHEREAS, in the matter of the Appeal of Charles Cory, on behalf of Big Steer Meats, to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1766 MINNEHAHA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 13-inch variance on the storage height clearance to the ceiling on the conditions that 1) the owner install a door closer for the door between the main business building and the storage building; and 2) provide a clearance of at least 9 inches for the full cinder block all the way around; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.