



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 22-27, **Version:** 2

Appeal of Barry W. Kostyk to a Fire Inspection Correction Notice at 351 HOPE STREET.

WHEREAS, in the matter of the Appeal of Barry W. Kostyk to a Fire Inspection Correction Notice at 351 Hope Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal pertaining to providing a 1-hour fire separation between the basement and first floor conditioned upon the hard-wired smoke alarm system being maintained, the continued presence of current smoke blocking barriers, such doors and ceiling construction and there being no combustible storage in basement areas which do not have 1-hour fire separation; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.