



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-226, **Version:** 2

Appeal of Shelly Pettit to a Fire Inspection Correction Notice at 777 HAZELWOOD STREET.

Openings meet standards in equivalence.

May 30, 2012

James Thomas

No hearing necessary.

Yes, 6 inches egress opening height.

WHEREAS, in the matter of the Appeal of Shelly Pettit to a Fire Inspection Correction Notice at 777 HAZELWOOD STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress bedroom window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.