



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-77, **Version:** 2

Appeal of Harmony Homes Inc. to an Egress Window Non-Compliance Determination at 1939 WELLESLEY AVENUE.

[Enter the Reason for the Appeal]

June 14, 2012

J. Hoffman

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Harmony Homes Inc. to an Egress Window Non-Compliance Determination at 1939 WELLESLEY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 19.75 inches high by 29 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.