



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-151, **Version:** 2

---

Appeal of Portoua Yang and Paul Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 995 CYPRESS STREET.

Only egress windows

August 12, 2011

Yes, 5 inch variance in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Nick Stark, to an Egress Window Non-Compliance Determination at 2057 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in all three bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.