



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-334, **Version:** 2

Appeal of Michael May to a Fire Certificate of Occupancy Inspection Correction Notice at 1026 GRAND AVENUE.

Basement ceiling height - less than 7 feet

August 12, 2011

Deny the appeal on the basement ceiling height.

WHEREAS, in the matter of Michael May to a Fire Certificate of Occupancy Inspection Correction Notice at 1026 GRAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the basement ceiling height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.